

Engine Data

29

Emission Unit Number	Emission Unit Description	Is this an emergency engine?	Construction Date	Engine Model Year	Brake Horsepower (bhp)
2250KW	Diesel Generator 2250 KW Caterpillar #3516B	Yes	completed June 1, 2005	model # 3516B 2004	2275

Existing units: Initial notifications are required to be submitted by August 31, 2010 for the following:

Area sources: Non-emergency engines > 300 bhp, installed before June 12, 2006

Major sources: Non-emergency engines > 500 bhp, installed before December 19, 2002, and
Non-emergency engines > 100 and ≤ 500 bhp, installed before June 12, 2006

New units: Initial notifications are required to be submitted within 120 days of startup for the following:

Major sources: All engines > 500 bhp installed on or after December 19, 2002

Signature

Responsible Official Certification		
<input checked="" type="checkbox"/>	I certify the truth, accuracy, and completeness of this notification.	
Responsible Official Name	Responsible Official Signature	Date
Chuck E. Christensen	Chuck E. Christensen	Aug 23, 2010

Submit this notification to the following agencies:

- Director, Air and Waste Management Division, U.S. Environmental Protection Agency, 901 N. 5th Street, Kansas City, KS 66101
- NESHAP Coordinator, Iowa Department of Natural Resources, 7900 Hickman, Suite 1; Windsor Heights, IA, 50324
- If the facility is located in either Linn County or Polk County, this notification shall also be submitted to the appropriate county office:

Polk County Public Works – Air Quality Division
5885 NE 14th Street; Des Moines, IA 50313

Linn County Public Health - Air Quality Division
501 13th Street NW; Cedar Rapids, IA 52405